


NOV 2012

(6/12)

Institute for Groundwater Studies

IGS Laboratory Services
 University of the Free State
 339, BLOEMFONTEIN, 9300
 +27-(0)51 - 401 2317
 +27-(0)51 - 444 6538 e-mail: igs@ufs.ac.za



Test Report

Client: Kareeberg Municipality		Page 1 of 2	
Contact: Frans Groenewald	Batch 3175		
Delivered by: Jackson Jantjies			
Date delivered: 11 December 2012			
Date sampled: 10 December 2012			
Determinand	Sample number:	SANS 241:2006&2011 specifications	Carmarvon Hospitaal
	Lab number:	value	K1
	Units		Value
Heterotrophic plate count	cfu/ml	1000	>1000
Total coliforms	cfu/ml	10	>201
<i>E.coli</i>	cfu/100ml	0	1
Bacterial note: All the parameters tested are within the specifications.			
Signed: _____			Date issued: 14 December 2012
This report relates only to the samples supplied to the Laboratory at the Institute for Groundwater Studies			