

Institute for Groundwater Studies

IGS Laboratory Services
 University of the Free State
 339, BLOEMFONTEIN, 9300
 +27-(0)51 - 401 2317
 +27-(0)51 - 401 3005 e-mail: igslab@ufs.ac.za



Test Report

Client: Kareeberg Municipality
Contact: Frans Groenewaldt
Reference: Case no 2013 -668
Delivered by: Frans Groenewaldt
Date delivered: 10 July 2013
Date sampled: 10 July 2013

Determinand	Sample number: Lab number:	SANS 241:2006&2011 specifications value	Carnarvon Hospitaal 668-1		Carnarvon Kliniek 668-2		Vanwyksvlei Mun kantoor 668-3		Vosburg Mun Kantoor 668-4	
			Units	Value	Value	Value	Value			
Heterotrophic plate count	cfu/ml	1000	3	1	>1000	0				
Total coliforms	cfu/ml	10	0	6	0	0				
E.coli	cfu/100ml	0	0	0	0	0				

Bacterial note: Parameters higher than the specifications, are clearly marked.

Signed: 
 H Human

This report relates only to the samples supplied to the Laboratory at the Institute for Groundwater Studies

Date issued: 12 July 2013