

Institute for Groundwater Studies

IGS Laboratory Services
 University of the Free State
 339, BLOEMFONTEIN, 9300
 +27-(0)51 - 401 2317
 +27-(0)51 - 401 3005
 e-mail: igs@ufs.ac.za



Test Report

Client: Kareeberg Municipality
Contact: Frans Groenewaldt
Reference: Case no 2013 -584
Delivered by: Jackson Jantjies
Date delivered: 13 June 2013
Date sampled: 13 June 2013

Determinand	Sample number: Lab number:	SANS 241:2006&2011 specifications value	Carnarvon Hospitaal 584-1		Vanwyksvlei Mun kantoor 584-2		Vosburg Mun Kantoor 584-3	
			Units	Value	Value	Value		
Heterotrophic plate count	cfu/ml	1000		0	11	5		
Total coliforms	cfu/ml	10		10	0	>201		
<i>E. coli</i>	cfu/100ml	0		0	0	0		

Bacterial note: All the parameters tested are within the specifications.

Signed: 
 L. Deyssel
 Date issued: 18 June 2013

This report relates only to the samples supplied to the Laboratory at the Institute for Groundwater Studies