

NOV 9/14

Institute for Groundwater Studies

IGS Laboratory Services
 University of the Free State
 339, BLOEMFONTEIN, 9300
 +27-(0)51 - 401 2317
 +27-(0)51 - 401 3005 e-mail: igs@ufs.ac.za



Test Report

Client: Kareeberg Municipality
Contact: Frans Groenewaldt
Delivered by: Frans Groenewaldt
Date delivered: 14 March 2013
Date sampled: 14 March 2013
 Case 2013-278

Determinand	Sample number: Lab number:	SANS 241:2006&2011 specifications value	Carnarvon Hospitaal 278-1		Carnarvon Kliniek 278-2		Vanwyksvlei Mun kantoor 278-3		Vosburg Mun Kantoor 278-4	
			Units	Value	Value	Value	Value			
Heterotrophic plate count	cfu/ml	1000	96	>1000	44	13				
Total coliforms	cfu/ml	10	0	1	14	11				
<i>E. coli</i>	cfu/100ml	0	0	0	4	0				

Bacterial note: All the parameters tested are within the specifications.
 Signed: _____
 L. Deysel
 This report relates only to the samples supplied to the Laboratory at the Institute for Groundwater Studies
 Date issued: 15 March 2013