

1 DV 13/11

Institute for Groundwater Studies

IGS Laboratory Services
 University of the Free State
 339, BLOEMFONTEIN, 9300
 +27-(0)51 - 401 2317
 +27-(0)51 - 401 3005 e-mail: igslab@ufs.ac.za



Test Report

Client: Kareeberg Municipality Page 1 of 3
 Contact: Frans Groenewaldt
 Reference: Case no 2013 -1167
 Delivered by: Frans Groenewaldt
 Date delivered: 14/11/2013
 Date sampled: 14/11/2013

Determinand	Sample number: Lab number:	SANS 241:2006&2011 specifications value	Carnarvon Hospitaal 1167-1		Carnarvon Kliniek 1167-2		Vanwyksvlei Mun kantoor 1167-3		Vosburg Mun Kantoor 1167-4	
			Units	Value	Value	Value	Value			
Heterotrophic plate count	cfu/ml	1000	10	0	0	>1000	16			
Total coliforms	cfu/ml	10	0	0	0	0	16			
E.coli	cfu/100ml	0	0	0	0	0	0			

Bacterial note: All the parameters tested are within the specifications.
 Signed: _____
 L. Deysel
 This report relates only to the samples supplied to the Laboratory at the Institute for Groundwater Studies
 Date issued: 18 November 2013