


100 14/8

Institute for Groundwater Studies

IGS Laboratory Services
 University of the Free State
 339, BLOEMFONTEIN, 9300
 +27-(0)51 - 401 2317
 +27-(0)51 - 401 3005 e-mail: igs1ab@ufs.ac.za



Test Report

Client: Kareeberg Municipality
 Contact: Frans Groenewaldt
 Reference: Case no 2013 -791
 Delivered by: Jackson Janijies
 Date delivered: 15 August 2013
 Date sampled: 15 August 2013

Determinand	Sample number:	SANS 241:2006&2011 specifications	Value			
			Units	Value	Value	Value
Heterotrophic plate count	cfu/ml	1000	6	4	46	0
Total coliforms	cfu/ml	10	0	1	0	0
<i>E.coli</i>	cfu/100ml	0	0	0	0	0

Bacterial note: All the parameters tested are within the specifications.
 Signed: _____
 L. Deyssel
 This report relates only to the samples supplied to the Laboratory at the Institute for Groundwater Studies
 Date issued: 19 August 2013