

NOV 17/13



# Institute for Groundwater Studies

IGS Laboratory Services  
 University of the Free State  
 339, BLOEMFONTEIN, 9300  
 +27-(0)51 - 401 2317  
 +27-(0)51 - 401 3005  
 e-mail: igslab@ufs.ac.za

## Test Report

**Client:** Kareeberg Municipality  
**Contact:** Frans Groenewaldt  
**Delivered by:** F Groenewaldt  
**Date delivered:** 15 May 2013  
**Date sampled:** 15 May 2013  
 Case 2013-463

Determinand	Sample number:	SANS specifications	Value			
			Carnarvon Hospitaal 463-1	Carnarvon Kliniek 463-2	Vanwyksvlei Mun kantoor 463-3	Vosburg Mun Kantoor 463-4
		241:2006&2011				
	Lab number:	value				
	Units					
Heterotrophic plate count	cfu/ml	1000	0	0	240	11
Total coliforms	cfu/ml	10	0	0	0	>201
<i>E.coli</i>	cfu/100ml	0	0	0	0	0

**Bacterial note:** All the parameters tested are within the specifications.

Signed: \_\_\_\_\_  
 L. Deyssel

This report relates only to the samples supplied to the Laboratory at the Institute for Groundwater Studies

Date issued: 16 May 2013