

NOV 21 10 5/11 AA

Institute for Groundwater Studies

IGS Laboratory Services
 University of the Free State
 339, BLOEMFONTEIN, 9300
 +27-(0)51 - 401 2317
 +27-(0)51 - 401 3005
 e-mail: igslab@ufs.ac.za



Test Report

Client: Kareeberg Municipality
Contact: Frans Groenewaldt
Reference: Case no 2013 -1052
Delivered by: Frans Groenewaldt
Date delivered: 18/10/2013
Date sampled: 18/10/2013

Determinand	Sample number:	SANS 241:2006&2011 specifications	Value			
	Lab number:		Units	Value	Value	Value
Heterotrophic plate count	cfu/ml	1000	Carnarvon Hospitaal 1052-1	Carnarvon Kliniek 1052-2	Vanwyksvlei Mun kantoor 1052-3	Vosburg Mun Kantoor 1052-4
	cfu/ml	10	42	0	129	3
	E.coli	0	0	0	0	0

Bacterial note: All the parameters tested are within the specifications.

Signed: _____
 L. Deysel

Date issued: 21 October 2013

This report relates only to the samples supplied to the Laboratory at the Institute for Groundwater Studies