

# Institute for Groundwater Studies

IGS Laboratory Services  
 University of the Free State  
 339, BLOEMFONTEIN, 9300  
 ☎ +27-(0)51 - 401 2317  
 📠 +27-(0)51 - 401 3005

e-mail: [igsilab@ufs.ac.za](mailto:igsilab@ufs.ac.za)



## Test Report

Client: Kareeberg Municipality

Page 1 of 3

Contact: Frans Groenewaldt

Reference: Case no 2014 -419

Delivered by: Jackson Jantjies 14:50

Date delivered: 15/04/2014

Date sampled: 14/04/2014

Determinand	Sample number: Lab number:	SANS 241:2006&2011 specifications	Carnarvon Hospital 419-1				Carnarvon Kliniek 419-2		Vanwyksvlei Mun kantoor 419-3	Vosburg Mun Kantoor 419-4
			Value	Value	Value	Value	Value	Value	Value	
Heterotrophic plate count	cfu/ml	1000	6	7	600	4			4	
Total coliforms	cfu/ml	10	4	3	0	4			4	
<i>E. coli</i>	cfu/100ml	0	✓ 0	0	0	1			✓	

Bacterial note: All the parameters not within the specifications are clearly marked.

Signed: *L. Deyssel*  
 L. Deyssel

Date issued: 15 April 2014  
 Final Report: 17 March 2014

This report relates only to the samples supplied to the Laboratory at the Institute for Groundwater Studies

*Handwritten notes:*  
 after PG  
 ok  
 17/03/14