


NOU 7/3
 Lab 7/3

Institute for Groundwater Studies

IGS Laboratory Services
 University of the Free State
 339, BLOEMFONTEIN, 9300
 +27-(0)51 - 401 2317
 +27-(0)51 - 401 3005

e-mail: igslab@ufs.ac.za



Test Report

Client: Kareeberg Municipality

Page 1 of 1

Contact: Frans Groenewaldt

Reference: Case no 2014 -172

Delivered by: Jackson Janjiles 15:30

Date delivered 13/02/2014

Date sampled: 12/02/2014

Determinand	Sample number:	SANS	Carnarvon				Vosburg Mun
	Lab number:	241:2006&2011 specifications	Hospital 172-1	Kliniek 172-2	Mun kantoor 172-3	Kantoor 172-4	
	Units	value	Value	Value	Value	Value	
Heterotrophic plate count	cfu/ml	1000	26	200	738	>1000	
Total coliforms	cfu/ml	10	2	>201	14	10	
<i>E.coli</i>	cfu/100ml	0	0	0	0	1	

Bacterial note: All the parameters not within the specifications are clearly marked.

Signed: _____ Date issued: 14 February 201
 L Deyse Final Report: 17 February 201

This report relates only to the samples supplied to the Laboratory at the Institute for Groundwater Studies