

Institute for Groundwater Studies

IGS Laboratory Services

University of the Free State

339, BLOEMFONTEIN, 9300

+27-(0)51 - 401 2317

+27-(0)51 - 401 3005

E-mail: igslab@ufs.ac.za

Test Report

Client: Kareeberg Municipality

Contact: Frans Groenewaldt

Reference: Case no 2014 -724

Delivered by: Frans & Elsabe Groenewald 12:15

Date delivered: 10/07/2014

Date sampled: 09/07/2014

Determinand	Sample number:	SANS 241:2006&2011 specifications	Carnarvon				Vanwyks' kant
			Hospitaal	Kliniek			
	Lab number:		724-1	724-2			
	Units	value	Value	Value			Val
Heterotrophic plate count		1000	34	0			>10
Total coliforms	cfu/ml	10	0	0			0
<i>E.coli</i>	cfu/100ml	0	0	0			0

Bacterial note: Parameters higher than the specifications, are clearly marked.

Signed: _____

L. Deyssel

This report relates only to the samples supplied to the Laboratory at the Institute for Groundwater Studies