

# Institute for Groundwater Studies

IGS Laboratory Services  
 University of the Free State  
 339, BLOEMFONTEIN, 9300  
 +27-(0)51 - 401 2317  
 +27-(0)51 - 401 3005  
 E-mail: [igslab@ufs.ac.za](mailto:igslab@ufs.ac.za)

## Test Report

**Client:** Kareeberg Municipality  
**Contact:** Frans Groenewald  
**Reference:** Case no 2014 - 650  
**Delivered by:** Frans 11:13  
**Date delivered:** 19/06/2014  
**Date sampled:** 18/06/2014

| Determinand               | Sample number: | SANS                         | Carnarvon       | Carnarvon     | Vanwyksvlei       |
|---------------------------|----------------|------------------------------|-----------------|---------------|-------------------|
|                           | Lab number:    | 241:2006&2011 specifications | Hospitaal 650-1 | Kliniek 650-2 | Mun kantoor 650-3 |
|                           | Units          | value                        | Value           | Value         | Value             |
| Heterotrophic plate count | cfu/ml         | 1000                         | 1               | 6             | >1000             |
| Total coliforms           | cfu/ml         | 10                           | 1               | 0             | 0                 |
| <i>E. coli</i>            | cfu/100ml      | 0                            | 0               | 0             | 0                 |

**Bacterial note:** The parameters higher than the specifications, are clearly marked.

Signed: \_\_\_\_\_  
 L Deyssel

Da: \_\_\_\_\_  
 Fin: \_\_\_\_\_

This report relates only to the samples supplied to the Laboratory at the Institute for Groundwater Studies