


* Failures - bring own incident file 14/14

Institute for Groundwater Studies

IGS Laboratory Services
 University of the Free State
 339, BLOEMFONTEIN, 9300
 ☎ +27-(0)51 - 401 2317
 📠 +27-(0)51 - 401 3005
 e-mail: igslab@ufs.ac.za




Test Report

Page 1 of 3

Client: Kareeberg Municipality
Contact: Frans Groenewaldt
Reference: Case no 2014 -517
Delivered by: Frans 12:11
Date delivered: 15/05/2014
Date sampled: 14/05/2014

Determinand	Sample number: Lab number:	SANS 241:2006&2011 specifications	Carnarvon				Vosburg Mun Kantoor 517-4 Value
			Hospitaal 517-1 Value	Kliniek 517-2 Value	Mun kantoor 517-3 Value		
Heterotrophic plate count	cfu/ml	1000	2	0	129	3	
Total coliforms	cfu/ml	10	0	0	0	1	
<i>E. coli</i>	cfu/100ml	0	0	0	0	0	

Bacterial note: All the parameters not within the specifications are clearly marked.

Signed: 
 L. Deyssel

Date issued: 16 May 2014
 Final Report: 19 May 2014

This report relates only to the samples supplied to the Laboratory at the Institute for Groundwater Studies