

Institute for Groundwater Studies

IGS Laboratory Services
 University of the Free State
 339, BLOEMFONTEIN, 9300
 +27-(0)51 - 401 2317
 +27-(0)51 - 401 3005 e-mail: igslab@ufs.ac.za



Test Report

Client: Kareeberg Municipality
 Contact: Frans Groenewaldt
 Reference: Case no 2014 -063
 Delivered by: Frans Groenewaldt
 Date delivered: 22/01/2014
 Date sampled: 22/01/2014

Determinand	Sample number: Lab number:	SANS 241:2006&2011 specifications	Carnarvon Hospitaal 063-1		Carnarvon Kliniek 063-2		Vamwyksvlie Mun kantoor 063-3		Vosburg Mun Kantoor 063-4	
			Units	Value	Value	Value	Value			
Heterotrophic plate count	cfu/ml	1000	33	12	>1000	9				
Total coliforms	cfu/ml	10	9	21	1	9				
<i>E.coli</i>	cfu/100ml	0	0	0	0	0				

Bacterial note: All the parameters tested are within the specifications.

Signed: L Deyssel
 Date issued: 24 January 2014
 Final Report: To follow

This report relates only to the samples supplied to the Laboratory at the Institute for Groundwater Studies