

2013 26/9

Institute for Groundwater Studies

IGS Laboratory Services
 University of the Free State
 339, BLOEMFONTEIN, 9300
 +27-(0)51 - 401 2317
 +27-(0)51 - 401 3005

e-mail: igslab@ufs.ac.za



Test Report

Client: Kareeberg Municipality
 Contact: Frans Groenewaldt
 Reference: Case no 2013 -882
 Delivered by: Frans Groenewaldt
 Date delivered: 05/09/2013
 Date sampled: 04/09/2013

Determinand	Sample number: Lab number:	SANS 241:2006&2011 specifications	Units		Value		Value	
			Value	Units	Value	Units	Value	Units
Heterotrophic plate count	cfu/ml	1000	1	cfu/ml	1	cfu/ml	1	cfu/ml
			0	cfu/ml	0	cfu/ml	0	cfu/ml
Total coliforms	cfu/ml	10	0	cfu/ml	0	cfu/ml	0	cfu/ml
			0	cfu/ml	0	cfu/ml	0	cfu/ml
E.coli	cfu/100ml	0	0	cfu/100ml	0	cfu/100ml	0	cfu/100ml
			0	cfu/100ml	0	cfu/100ml	0	cfu/100ml

Bacterial note: All the parameters tested are within the specifications.
 Signed: _____
 L. Deyzel
 Date issued: 9 September 2013

This report relates only to the samples supplied to the Laboratory at the Institute for Groundwater Studies