

Institute for Groundwater Studies

IGS Laboratory Services
University of the Free State
✉ 339, BLOEMFONTEIN, 9300
☎ +27-(0)51 - 401 2317
☎: +27-(0)51 - 401 3005

E-mail: igslab@ufs.ac.za



Test Report

Client: Kareeberg Municipality
Contact: Frans Groenewald
Reference: **Case no 2014 - 650**
Delivered by: Frans 11:13
Date delivered: 19/06/2014
Date sampled: 18/06/2014

Page 1 of 3

Determinand	Sample number:	SANS 241:2006&2011 specifications	Carnarvon Hospitaal	Carnarvon Kliniek	Vanwyksvlei Mun kantoor	Vosburg Mun Kantoor
	Lab number:		650-1	650-2	650-3	650-4
	Units	value	Value	Value	Value	Value
Heterotrophic plate count	cfu/ml	1000	1	6	>1000	0
Total coliforms	cfu/ml	10	1	0	0	2
<i>E.coli</i>	cfu/100ml	0	0	0	0	0

Bacterial note: The parameters higher than the specifications, are clearly **marked**.

Signed: _____

L Deysel

Date issued: 20 June 2014

Final Report: 23 June 2014

This report relates only to the samples supplied to the Laboratory at the Institute for Groundwater Studies