

Institute for Groundwater Studies

IGS Laboratory Services
 University of the Free State
 339, BLOEMFONTEIN, 9300
 +27-(0)51 - 401 2317
 +27-(0)51 - 444 6538 e-mail: igslab@ufs.ac.za



Test Report

Client: Kareeberg Municipality
 Contact: Frans Groenewald
 Delivered by: Frans Groenewald
 Date delivered: 16 October 2012
 Date sampled: 17 October 2012
 Batch 2287

Determinand	Sample number:	SANS 241:2006&2011 specifications	Carnarvon Hospitaal K1	Carnarvon Kliniek K2	Carnarvon Johannastr 10 K3	Van Wyksvlei Mun Kantoor K4	Vosburg Mun Kantoor K5
	Lab number:	value	Value	Value	Value	Value	Value
Heterotrophic plate count		1000	0	0	>1000	>1000	9
Total coliforms		10	0	0	>201	0	1
E.coli		0	0	0	0	0	0

Bacterial note: All the parameters tested are within the specifications.

Signed: *L. Deyzel*
 L. Deyzel

Date issued: 19 October 2012

This report relates only to the samples supplied to the Laboratory at the Institute for Groundwater Studies